## **2022 ANNUAL NOTICE TO CONSUMERS**

## VILLAGE OF ZENON PARK

BACTERIOLOGICAL SAMPLING-\*one sample must be submitted twice every month 1.

> 24 Samples Required Samples Submitted 34 0 # of Positive Samples

2. WATER TREATMENT PLANT - FREE CHLORINE DATA-\*free chlorine minimum level -0.1mg/l

> CI Tests Required 365 365 CI Tests Recorded

0 \* taken at the time of the depressurization # of Low Chlorine (less than 0.1mg/l)

Free Chlorine Range (lowest to highest) 0.11mg/l to 2.28 mg/l

TREATMENT PLANT-TURBIDITY DATA-\*max. turbidity not to exceed 1.0 NTU 3.

> **Turbidity Tests Required** 365 365 **Turbidity Tests Recorded Turbidity Exceedance** 0

0.09NTU to 1.74NTU Turbidity Range (lowest to highest)

DISTRIBUTION SYSTEM CHLORINE DATA 4.

> Chlorine Tests Required 24 Chlorine Tests Submitted 34 # of Low Chlorine Levels

5. GENERAL CHEMICAL TESTS-\*these substances are not regulated however some may represent a health risk to some people if found in excessive concentrations -\*all waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every

two years

**Date Sample Submitted** August 8, 2022

Exceedance

6. HEALTH & TOXICITY TEST-\*one sample required every two years **Date Sample Submitted** 

August 8, 2022

Exceedance

THE COUNCIL OF THE VILLAGE OF ZENON PARK

<sup>\*</sup>for more detailed information, complete results are available at the Village Office or at www.saskh2o.ca