

2023 ANNUAL NOTICE TO CONSUMERS

VILLAGE OF ZENON PARK

1. BACTERIOLOGICAL SAMPLING-*one sample must be submitted twice every month
Samples Required 24
Samples Submitted 24
of Positive Samples 0
2. WATER TREATMENT PLANT – FREE CHLORINE DATA-*free chlorine minimum level -0.1mg/l
Cl Tests Required 365
Cl Tests Recorded 363
of Low Chlorine (less than 0.1mg/l) 0 * taken at the time of the depressurization
Free Chlorine Range (lowest to highest) 0.4mg/l to 2.83 mg/l
3. WATER TREATMENT PLANT-TURBIDITY DATA-*max. turbidity not to exceed 1.0 NTU
Turbidity Tests Required 365
Turbidity Tests Recorded 363
Turbidity Exceedance 0
Turbidity Range (lowest to highest) 0.11NTU to 1.31NTU
4. DISTRIBUTION SYSTEM CHLORINE DATA
Chlorine Tests Required 24
Chlorine Tests Submitted 24
of Low Chlorine Levels 0
5. GENERAL CHEMICAL TESTS-*these substances are not regulated however some may represent a health risk to some people if found in excessive concentrations -*all waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years
Date Sample Submitted August 8, 2022
Exceedance 0
6. HEALTH & TOXICITY TEST-*one sample required every two years
Date Sample Submitted August 8, 2022
Exceedance 0

*for more detailed information, complete results are available at the Village Office

THE COUNCIL OF THE VILLAGE OF ZENON PARK

2023 ANNUAL NOTICE TO CONSUMERS

VILLAGE OF ZENON PARK

1. BACTERIOLOGICAL SAMPLING-*one sample must be submitted twice every month
Samples Required 24
Samples Submitted 24
of Positive Samples 0
2. WATER TREATMENT PLANT – FREE CHLORINE DATA-*free chlorine minimum level -0.1mg/l
Cl Tests Required 365
Cl Tests Recorded 363
of Low Chlorine (less than 0.1mg/l) 0 * taken at the time of the depressurization
Free Chlorine Range (lowest to highest) 0.4mg/l to 2.83 mg/l
3. WATER TREATMENT PLANT-TURBIDITY DATA-*max. turbidity not to exceed 1.0 NTU
Turbidity Tests Required 365
Turbidity Tests Recorded 363
Turbidity Exceedance 0
Turbidity Range (lowest to highest) 0.11NTU to 1.31NTU
4. DISTRIBUTION SYSTEM CHLORINE DATA
Chlorine Tests Required 24
Chlorine Tests Submitted 24
of Low Chlorine Levels 0
5. GENERAL CHEMICAL TESTS-*these substances are not regulated however some may represent a health risk to some people if found in excessive concentrations -*all waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years
Date Sample Submitted August 8, 2022
Exceedance 0
6. HEALTH & TOXICITY TEST-*one sample required every two years
Date Sample Submitted August 8, 2022
Exceedance 0

*for more detailed information, complete results are available at the Village Office

THE COUNCIL OF THE VILLAGE OF ZENON PARK